

## South East South Australia Pipeline

### Receipt and Delivery Points

#### Receipt Points

Name	Location	Pressure (kPa)	Physical Capacity (GJ/Day)	Zone
			[see note 1]	[see note 2]
Poolajelo Receipt Point	The interconnection point between the SEAGas Pipeline and the South East South Australia Pipeline	Minimum: 6,720 Maximum: 9,300	40,000	SESA-RZ-01

#### Delivery Points

Name	Location	Pressure (kPa)	Physical Capacity (GJ/Day)	Temperature (°C)	Zone
			[see note 1]		[see note 2]
Epic Energy MLV Compound (South East Pipeline) Delivery Point	The insulating joint immediately upstream of the Epic Energy MLV Compound	Minimum: 4,950 Maximum: 6,200	16,000	0-50	SESA-DZ-01
Ladbroke Grove Power Station GT1 Delivery Point	The insulating joint immediately upstream of the Ladbroke Grove Power Station Compound for GT1	Minimum: 4,520 Maximum: 4,790	12,000	30-80	SESA-DZ-01
Ladbroke Grove Power Station GT2 Delivery Point	The insulating joint immediately upstream of the Ladbroke Grove	Minimum: 4,520 Maximum: 4,790	12,000	30-80	SESA-DZ-01

	Power Station Compound for GT2				
--	--------------------------------------	--	--	--	--

Note 1: Hourly Physical Capacity unless otherwise stated is the Physical Capacity at the point divided by 24 and multiplied by the MHQ Factor for the Facility as set out in Schedule 10 of the Facility Specific Terms.

Note 2: Zones descriptions are accurate as at 1 July 2023, however are subject to change in accordance with the National Gas Rules. The zone information published in the AEMO Transportation Service Point Register prevails in the event of an inconsistency.